

TECHNICAL INFORMATION	TI-HMI-0011v100EN
How to clean and disinfect the touch panel surface	

Type	HMI
Software version	All versions
Required options	Not required
Use	Fuji technical staff / Web
Date	17/06/2020
Version	1.0.0
Author	Gustavo Martínez
Revised	José María Delgado
Approved	José María Delgado
Languages	English

How to clean and disinfect the touch panel surface

Wipe down the surface using a soft cloth dampened with commercial alcohol or ethanol.



* The optional protective sheet, "V9xxx-GS" and "V9xxx-GSN10", can be cleaned and disinfected in the same way.

1- Descriptions of cleaning and disinfecting

- Turn OFF power to the MONITOUCH before cleaning and disinfecting.
- Do not apply the solution directly to the surface of the touch panel. Dampen a soft cloth with alcohol or ethanol, and wipe slowly.
- Take care not to rub the housing strongly.
- Check whether the solution is dry before turning ON power to the MONITOUCH.

2- If the alcohol or ethanol is not available

- Use the following solutions.
 - a- Hypochlorous acid solution
 - b- 0.02% sodium hypochlorite solution

* Following solutions are not available for the MONITOUCH.

Cleaner containing surfactant

Organic solvent including acetone, thinners, benzene, etc.

- Don't apply hypochlorous acid solution and sodium hypochlorite on the surface of the control panel.
It may cause paint deterioration or corrosion of the surface.
- Dilute sodium hypochlorite before use.
Using the undiluted solution may cause the deformation or dissolution of the panel sheet and housing.

Document history.

Version	Changes applied	Date	Written	Revised	Approved