LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 1683a

Issue: 01

PRE

Reacton Fire Suppression Ltd

14 Baynes Place Waterhouse Business Park Chelmsford Essex CM1 2QX United Kingdom

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Direct Low Pressure (DLP) Application FixedLPS 1666: Issue 1.0Fire Suppression SystemsRequirements and test
approval of direct low

Standards

LPS 1666: Issue 1.0 Requirements and test procedures for the LPCB approval of direct low pressure (DLP) application fixed fire suppression systems.

This certificate and appendix is maintained and held in force through regular surveillance activities

| S.A.C.L.well | Sarah Colwell | 14 January 2022 | 14 January 2022 | | | |
|--|--|---|---------------------|--|--|--|
| Signed for BRE Global Ltd. | Verifier | Date of Issue | Date of First Issue | | | |
| AND CERTIFICATION ON CERTIFICATION OF THE PERTIFICATION OF THE PERTIFICA | This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms)</u> . To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u> , scan the QR tag or contact us. | | | | | |
| | BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com | | | | | |
| | LPCB is a Registered Tradema | rk of the Building Research Establishment L | td. DIC | | | |
| | | | | | | |

© BRE Global Ltd, 2022

LPCB®

Appendix to Certificate No: 1683a Reacton Fire Suppression Ltd

Issue: 01

Reacton Fire Suppression FK-5-1-12 Direct Low Pressure (DLP) Application Fixed Fire Suppression Systems

| Product Name | Contain er Size | Description | Detector Tube | Ventilation (Enclosed or Open Vents) | Air Flow (Forced / Natural) | LPCB Ref. No. |
|-------------------|--------------------|------------------------------|------------------------|--|-----------------------------------|------------------|
| RE-CT-014-010-FK5 | 1.4 Litre | 1 kg FK-5-1-12 DLP system | P/N: RE7211 6mm o/d | Enclosed & open options ⁴ | Forced & natural ⁵ | 1683a/01 |
| RE-CT-026-020-FK5 | 2.6 Litre | 2 kg FK-5-1-12 DLP system | P/N: RE7211 6mm o/d | Enclosed & open options ⁴ | Forced & natural ⁵ | 1683a/02 |
| RE-CT-048-030-FK5 | 4.8 Litre | 3 kg FK-5-1-12 DLP system | P/N: RE7211 6mm o/d | Enclosed & open options ⁴ | Forced & natural ⁵ | 1683a/03 |
| RE-CT-048-040-FK5 | 4.8 Litre | 4 kg FK-5-1-12 DLP system | P/N: RE7211 6mm o/d | Enclosed & open options ⁴ | Forced & natural ⁵ | 1683a/04 |
| RE-CT-075-060-FK5 | 7.5 Litre | 6 kg FK-5-1-12 DLP system | P/N: RE7211 6mm o/d | Enclosed & open options ⁴ | Forced & natural ⁵ | 1683a/05 |

Notes:

1. Reacton Fire Suppression Ltd DLP Systems shall be configured, installed, serviced and maintained in accordance with:

- Design, Installation, Operation and Maintenance Manual: DOC USM0019 Rev B, Date: 01/06/2021.
 - Design Requirement Sheet LPS1666: DOC DRS0001 Rev C, Date:01/06/2021
- 2. These systems are intended solely to provide enhanced local fire protection. They are not intended for use as whole room or building fire protection systems.
- 3. The systems use a single method for detection and delivery of the extinguishing agent to the activation point.
 - System operation pressure: 15 bar @ 20°C.
 - System operation temperature range: -20°C to +60°C.
- 4. The above systems may have air vents at low and/or high level (refer note 1).
- 5. The above systems may have forced ventilation (refer note 1).

This certificate and appendix is maintained and held in force through regular surveillance activities

