


## Ventilation Assessment Summary

### Ventilation Assessment



#	HVAC		Site		Air Changes			Recommendation		Mitigation
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply	Applied CADR
1	<a href="#">B24</a>	Office	District Offices	Finance & HR	3	4.0	Meets target	0	87	0
2	<a href="#">B23</a>	Office	District Offices	Finance & HR	3	8.9	Meets target	0	70	0
3	<a href="#">B22</a>	Office	District Offices	Finance & HR	3	8.1	Meets target	0	70	0
4	<a href="#">B21</a>	Office	District Offices	Finance & HR	3	8.2	Meets target	0	69	0
5	<a href="#">B20</a>	Office	District Offices	Finance & HR	3	3.7	Meets target	0	69	0
6	<a href="#">B19</a>	Office	District Offices	Finance & HR	3	6.0	Meets target	0	105	0
7	<a href="#">B26D</a>	Office	District Offices	Finance & HR	3	14.8	Meets target with mitigation	19	42	167
8	<a href="#">B26E</a>	Office	District Offices	Finance & HR	3	3.6	Meets target	0	43	0
9	<a href="#">B25A</a>	Conference	District Offices	Finance & HR	3	7.6	Meets target with mitigation	39	92	167
10	<a href="#">HR Lobby / Cubicle Office</a>	Office	District Offices	Finance & HR	3	3.4	Meets target with mitigation	428	986	558
11	<a href="#">B17A</a>	Office	District Offices	Finance & HR	3	7.0	Meets target	0	65	0
12	<a href="#">Payroll</a>	Office	District Offices	Finance & HR	3	8.2	Meets target	0	357	0
13	<a href="#">B16</a>	Office	District Offices	Finance & HR	3	7.3	Meets target	0	104	0
14	<a href="#">B11</a>	Office	District Offices	Finance & HR	3	3.0	Meets target	0	69	0
15	<a href="#">B10</a>	Office	District Offices	Finance & HR	3	8.1	Meets target with mitigation	62	68	167
16	<a href="#">B13</a>	Office	District Offices	Finance & HR	3	3.0	Meets target	8	69	0
17	<a href="#">B14</a>	Office	District Offices	Finance & HR	3	7.8	Meets target	0	67	0
18	<a href="#">B15</a>	Office	District Offices	Finance & HR	3	8.6	Meets target	0	71	0
19	<a href="#">A26</a>	Office	District Offices	Finance & HR	3	6.1	Meets target	0	126	0
20	<a href="#">A1</a>	Lecture Room	District Offices	Finance & HR	4	4.5	Meets target with mitigation	1000	1101	1116
21	<a href="#">B1M</a>	Office	District Offices	Finance & HR	3	13.4	Meets target	0	52	0
22	<a href="#">B1J</a>	Office	District Offices	Finance & HR	3	9.1	Meets target	0	71	0
23	<a href="#">B1C</a>	Conference	District Offices	Finance & HR	3	8.1	Meets target	0	71	0
24	<a href="#">B1B</a>	Office	District Offices	Finance & HR	3	4.5	Meets target	0	45	0

#	HVAC		Site		Air Changes			Recommendation		Mitigation
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply	Applied CADR
25	<a href="#">B1A</a>	Office	District Offices	Finance & HR	3	11.8	Meets target	0	48	0
26	<a href="#">B1L</a>	Office	District Offices	Finance & HR	3	10.1	Meets target	0	53	0
27	<a href="#">B1K</a>	Office	District Offices	Finance & HR	3	4.7	Meets target	0	134	0
28	<a href="#">B1H</a>	Office	District Offices	Finance & HR	3	9.1	Meets target	0	68	0
29	<a href="#">B1G</a>	Office	District Offices	Finance & HR	3	8.5	Meets target with mitigation	3	100	167
30	<a href="#">B1F</a>	Office	District Offices	Finance & HR	3	7.1	Meets target	0	47	0
31	<a href="#">B1E</a>	Office	District Offices	Finance & HR	3	14.2	Meets target	0	48	0
32	<a href="#">B1D</a>	Office	District Offices	Finance & HR	3	10.5	Meets target	0	68	0
33	<a href="#">C5</a>	Office	District Offices	Finance & HR	3	11.7	Meets target with mitigation	43	47	167
34	<a href="#">C4</a>	Office	District Offices	Finance & HR	3	10.3	Meets target with mitigation	49	53	167
35	<a href="#">C7</a>	Conference	District Offices	Finance & HR	3	4.3	Meets target with mitigation	117	129	167
36	<a href="#">A17</a>	Break room	District Offices	Finance & HR	3	8.1	Meets target	0	313	0
37	<a href="#">C3B</a>	Office	District Offices	Finance & HR	3	10.0	Meets target with mitigation	50	55	167
38	<a href="#">A5</a>	Office	District Offices	Finance & HR	3	6.9	Meets target	0	195	0
39	<a href="#">A14A</a>	Conference	District Offices	Finance & HR	3	7.6	Meets target	0	187	0
40	<a href="#">A11</a>	Office	District Offices	Finance & HR	3	7.3	Meets target with mitigation	69	76	167
41	<a href="#">A12</a>	Kitchen	District Offices	Finance & HR	3	5.6	Meets target with mitigation	90	99	167
42	<a href="#">A9A</a>	Office	District Offices	Finance & HR	3	11.5	Meets target with mitigation	44	48	167
43	<a href="#">C3A</a>	Office	District Offices	Finance & HR	3	10.3	Meets target with mitigation	49	53	167
44	<a href="#">C3C</a>	Office	District Offices	Finance & HR	3	9.3	Meets target with mitigation	54	59	167
45	<a href="#">A23</a>	Office	District Offices	Finance & HR	3	8.4	Meets target with mitigation	60	66	167
46	<a href="#">A21</a>	Break room	District Offices	Finance & HR	3	7.7	Meets target with mitigation	65	72	167
47	<a href="#">A25</a>	Office	District Offices	Finance & HR	3	3.4	Meets target with mitigation	248	272	279
48	<a href="#">S38</a>	Office	District Offices	Finance & HR	3	3.9	Meets target with mitigation	216	238	279
49	<a href="#">S33</a>	Office	District Offices	Finance & HR	3	10.0	Meets target with mitigation	26	67	167
50	<a href="#">S37</a>	Office	District Offices	Finance & HR	3	8.1	Meets target with mitigation	62	68	167
51	<a href="#">S36</a>	Office	District Offices	Finance & HR	3	6.6	Meets target	0	67	0
52	<a href="#">S31</a>	Office	District Offices	Finance & HR	3	14.1	Meets target	0	61	0
53	<a href="#">S34</a>	Break room	District Offices	Finance & HR	3	8.5	Meets target with mitigation	59	65	167

53

53