


# Ventilation Assessment Summary

## Ventilation Assessment



#	HVAC		Site		Air Changes			Recommendation		Mitigation
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply	Applied CADR
1	<a href="#">A201</a>	Reception Areas	Laney College	A Complex	3	4.0	Meets target with mitigation	336	597	460
2	<a href="#">A203</a>	Classroom	Laney College	A Complex	3	6.3	Meets target	0	825	0
3	<a href="#">A201A</a>	Office	Laney College	A Complex	3	4.0	Meets target with mitigation	298	510	460
4	<a href="#">A202</a>	Office	Laney College	A Complex	3	5.1	Meets target	0	1278	0
5	<a href="#">A203A</a>	Office	Laney College	A Complex	3	9.8	Meets target	0	72	0
6	<a href="#">A202B</a>	Office	Laney College	A Complex	3	17.5	Meets target	0	70	0
7	<a href="#">A203B</a>	Office	Laney College	A Complex	3	11.0	Meets target	0	68	0
8	<a href="#">A203C</a>	Break room	Laney College	A Complex	3	3.2	Meets target	0	100	0
9	<a href="#">A204</a>	Classroom	Laney College	A Complex	3	3.8	Meets target with mitigation	514	734	690
10	<a href="#">A236</a>	Science Lab	Laney College	A Complex	3	4.2	Meets target	0	848	0
11	<a href="#">A237A</a>	Office	Laney College	A Complex	3	13.0	Meets target	0	70	0
12	<a href="#">A204A</a>	Office	Laney College	A Complex	3	15.7	Meets target	0	30	0
13	<a href="#">A204B</a>	Office	Laney College	A Complex	3	6.5	Meets target	0	51	0
14	<a href="#">A236A</a>	Office	Laney College	A Complex	3	12.7	Meets target	0	69	0
15	<a href="#">A235</a>	Science Lab	Laney College	A Complex	3	14.2	Meets target	0	711	0
16	<a href="#">A235B</a>	Science Lab	Laney College	A Complex	3	5.1	Meets target	0	290	0
17	<a href="#">A239</a>	Classroom	Laney College	A Complex	6	7.1	Meets target	0	642	0
18	<a href="#">A279</a>	Occupiable Storage (I	Laney College	A Complex	3	12.0	Meets target	0	159	0
19	<a href="#">A270</a>	Office	Laney College	A Complex	3	11.0	Meets target	0	71	0
20	<a href="#">A272</a>	Science Lab	Laney College	A Complex	3	6.0	Meets target	0	271	0
21	<a href="#">A278</a>	Occupiable Storage (I	Laney College	A Complex	3	13.4	Meets target	0	162	0
22	<a href="#">A271</a>	Science Lab	Laney College	A Complex	4	4.1	Meets target	0	641	0
23	<a href="#">A273</a>	Lecture Room	Laney College	A Complex	3	10.9	Meets target	0	248	0
24	<a href="#">A277</a>	Science Lab	Laney College	A Complex	3	8.4	Meets target	0	688	0
25	<a href="#">A274</a>	Science Lab	Laney College	A Complex	4	11.2	Meets target	0	644	0
26	<a href="#">A277A</a>	Science Lab	Laney College	A Complex	3	10.9	Meets target with mitigation	8	66	167
27	<a href="#">A275</a>	Office	Laney College	A Complex	3	13.7	Meets target	0	73	0
28	<a href="#">A276</a>	Office	Laney College	A Complex	3	13.4	Meets target	0	72	0
29	<a href="#">A266</a>	Classroom	Laney College	A Complex	5	5.8	Meets target with mitigation	97	888	230

#	HVAC		Site		Air Changes			Recommendation		Mitigation
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply	Applied CADR
30	<a href="#">A185</a>	Office	Laney College	A Complex	3	3.0	Meets target	10	56	0
31	<a href="#">A184</a>	Classroom	Laney College	A Complex	5	9.4	Meets target with mitigation	122	135	230
32	<a href="#">A183</a>	Computer Lab	Laney College	A Complex	4	10.0	Meets target with mitigation	92	101	230
33	<a href="#">o Hallways and Common A</a>	Lobby	Laney College	A Complex	3	3.7	Meets target with mitigation	358	514	460
34	<a href="#">A237</a>	Science Lab	Laney College	A Complex	3	4.2	Meets target	0	710	0
35	<a href="#">A164</a>	Science Lab	Laney College	A Complex	3	25.1	Meets target with mitigation	20	22	167
36	<a href="#">A165</a>	Science Lab	Laney College	A Complex	3	34.5	Meets target with mitigation	20	22	230
37	<a href="#">A166</a>	Science Lab	Laney College	A Complex	3	33.0	Meets target with mitigation	20	22	220
38	<a href="#">A167</a>	Science Lab	Laney College	A Complex	3	34.5	Meets target with mitigation	20	22	230
39	<a href="#">A168</a>	Science Lab	Laney College	A Complex	3	15.8	Meets target with mitigation	44	48	230
40	<a href="#">A170</a>	Science Lab	Laney College	A Complex	6	34.5	Meets target with mitigation	40	44	230
41	<a href="#">A169</a>	Science Lab	Laney College	A Complex	6	34.5	Meets target with mitigation	40	44	230
42	<a href="#">A171</a>	Science Lab	Laney College	A Complex	6	34.5	Meets target with mitigation	40	44	230
43	<a href="#">A172</a>	Science Lab	Laney College	A Complex	3	34.5	Meets target with mitigation	20	22	230
44	<a href="#">A173</a>	Science Lab	Laney College	A Complex	3	25.1	Meets target with mitigation	20	22	167
45	<a href="#">A174</a>	Science Lab	Laney College	A Complex	3	16.4	Meets target with mitigation	42	46	230
46	<a href="#">A177</a>	Office	Laney College	A Complex	3	16.9	Meets target with mitigation	41	45	230
47	<a href="#">A179 / A180</a>	Lecture Room	Laney College	A Complex	3	3.2	Meets target with mitigation	822	1609	920
48	<a href="#">A178 / A162</a>	Science Lab	Laney College	A Complex	4	4.2	Meets target with mitigation	440	484	460
49	<a href="#">A165</a>	Science Lab	Laney College	A Complex	3	34.5	Meets target with mitigation	20	22	230
50	<a href="#">A190</a>	Occupiable Storage (L	Laney College	A Complex	3	7.1	Meets target	0	119	0
51	<a href="#">A192</a>	Office	Laney College	A Complex	3	3.5	Meets target	0	53	0
52	<a href="#">A191A/ A191B</a>	Science Lab	Laney College	A Complex	3	10.7	Meets target	0	1468	0
53	<a href="#">A191C / A192</a>	Science Lab	Laney College	A Complex	3	12.6	Meets target	0	1192	0
54	<a href="#">A153 / A154</a>	Art Classroom	Laney College	A Complex	3	4.4	Meets target	0	2959	0
55	<a href="#">A152</a>	Art Classroom	Laney College	A Complex	3	9.9	Meets target	0	2412	0
56	<a href="#">A151</a>	Office	Laney College	A Complex	3	5.1	Meets target	0	67	0
57	<a href="#">A140</a>	Classroom	Laney College	A Complex	4	17.2	Meets target	0	241	0
58	<a href="#">A150-A154</a>	Reception Areas	Laney College	A Complex	3	3.1	Meets target with mitigation	899	1266	950
59	<a href="#">A105</a>	Lecture Room	Laney College	A Complex	3	5.8	Meets target	0	1275	0
60	<a href="#">A101A</a>	Office	Laney College	A Complex	3	5.0	Meets target	187	187	0
61	<a href="#">A107</a>	Office	Laney College	A Complex	3	3.5	Meets target	0	54	0
62	<a href="#">A106 Lobby</a>	Reception Areas	Laney College	A Complex	3	3.4	Meets target	0	562	0
63	<a href="#">A101B</a>	Reception Areas	Laney College	A Complex	3	8.6	Meets target	0	691	0
64	<a href="#">A106B</a>	Office	Laney College	A Complex	3	4.9	Meets target with mitigation	99	230	230
65	<a href="#">A106A</a>	Office	Laney College	A Complex	3	3.2	Meets target	0	109	0
66	<a href="#">A101B Office</a>	Office	Laney College	A Complex	3	3.1	Meets target	0	128	0
67	<a href="#">A108</a>	Office	Laney College	A Complex	3	4.5	Meets target	0	53	0