




## Ventilation Assessment Summary

### Ventilation Assessment



#	HVAC		Site		Air Changes			Recommendation	
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply
1	<a href="#">AC110</a>	Art Classroom	Laney College	Art Center	4	0.0	Does not meet target	648	714
2	<a href="#">AC112</a>	Classroom	Laney College	Art Center	3	0.0	Does not meet target	513	564
3	<a href="#">AC101</a>	Art Classroom	Laney College	Art Center	3	0.0	Does not meet target	73	80
4	<a href="#">AC100</a>	Art Classroom	Laney College	Art Center	3	0.0	Does not meet target	2586	2846
5	<a href="#">AC102</a>	Occupiable Storage (Dry)	Laney College	Art Center	3	0.0	Does not meet target	71	78
6	<a href="#">AC103</a>	Office	Laney College	Art Center	3	0.0	Does not meet target	107	118
7	<a href="#">AC113</a>	Office	Laney College	Art Center	3	0.0	Does not meet target	45	50
8	<a href="#">AC120</a>	Art Classroom	Laney College	Art Center	3	0.6	Does not meet target	877	1201
9	<a href="#">AC121</a>	Office	Laney College	Art Center	3	0.0	Does not meet target	65	72
10	<a href="#">AC122</a>	Occupiable Storage (Dry)	Laney College	Art Center	3	0.0	Does not meet target	110	121
11	<a href="#">AC125</a>	Art Classroom	Laney College	Art Center	3	0.0	Does not meet target	1253	1379
12	<a href="#">AC126</a>	Office	Laney College	Art Center	3	0.0	Does not meet target	66	73
13	<a href="#">AC127</a>	Occupiable Storage (Dry)	Laney College	Art Center	3	0.0	Does not meet target	103	113
14	<a href="#">AC132</a>	Office	Laney College	Art Center	3	0.0	Does not meet target	96	105
15	<a href="#">AC135</a>	Art Classroom	Laney College	Art Center	3	0.0	Does not meet target	2243	2469
16	<a href="#">AC130</a>	Art Classroom	Laney College	Art Center	3	0.0	Does not meet target	1539	1694
17	<a href="#">AC136</a>	Occupiable Storage (Dry)	Laney College	Art Center	3	0.0	Does not meet target	155	171
18	<a href="#">AC137</a>	Office	Laney College	Art Center	3	0.0	Does not meet target	84	93
19	<a href="#">AC138</a>	Kitchen	Laney College	Art Center	3	0.0	Does not meet target	875	963
20	<a href="#">AC139</a>	Occupiable Storage (Dry)	Laney College	Art Center	3	0.0	Does not meet target	269	296
21	<a href="#">AC140</a>	Art Classroom	Laney College	Art Center	3	0.0	Does not meet target	140	154
22	<a href="#">A140A</a>	Occupiable Storage (Dry)	Laney College	Art Center	3	0.0	Does not meet target	109	119