




Ventilation Assessment Summary

Ventilation Assessment



#	HVAC		Site		Air Changes			Recommendation	
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply
1	Forum	Lecture Room	Laney College	Forum	3	4.4	Meets target	0	3577