




Ventilation Assessment Summary

Ventilation Assessment



#	HVAC		Site		Air Changes			Recommendation		Mitigation
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	Min. Supply	Applied CADR
1	SC300A	Office	Laney College	Student Center	3	14.4	Meets target	0	382	0
2	SC401B	Conference	Laney College	Student Center	3	9.0	Meets target	0	258	0
3	SC411	Office	Laney College	Student Center	3	3.6	Meets target	0	276	0
4	SC417	Break room	Laney College	Student Center	3	23.7	Meets target	0	37	0
5	SC403	Break room	Laney College	Student Center	3	5.2	Meets target with mitigation	132	145	230
6	SC301A/SC301B/SC327	Office	Laney College	Student Center	3	12.6	Meets target	0	329	0
7	SC301	Conference	Laney College	Student Center	3	16.9	Meets target	0	152	0
8	SC413	Office	Laney College	Student Center	3	10.6	Meets target	0	72	0
9	Main Dining Area 201	Cafeteria	Laney College	Student Center	3	3.2	Meets target with mitigation	2589	5110	2850
10	Lounge & Dining 300	Cafeteria	Laney College	Student Center	3	3.3	Meets target with mitigation	539	1971	690
11	SC201,SC202,SC203,SC212	Kitchen	Laney College	Student Center	3	4.0	Meets target	0	1343	0
12	SC414	Office	Laney College	Student Center	3	7.1	Meets target	0	54	0
13	SC415	Office	Laney College	Student Center	3	22.2	Meets target	0	63	0
14	STORAGE	Occupiable Storage (C	Laney College	Student Center	3	9.6	Meets target	0	45	0
15	SC123	Office	Laney College	Student Center	3	4.8	Meets target	0	85	0
16	SC110	Library	Laney College	Student Center	3	4.4	Meets target	0	2639	0
17	SC402	Office	Laney College	Student Center	3	3.4	Meets target	0	145	0
18	SC401A	Conference	Laney College	Student Center	3	3.0	Meets target	14	230	0
19	SC110A	Office	Laney College	Student Center	3	7.0	Meets target	0	115	0
20	SC412	Office	Laney College	Student Center	3	12.3	Meets target	0	70	0
21	SC125	Office	Laney College	Student Center	3	4.1	Meets target with mitigation	168	185	230
22	SC130	Locker Room	Laney College	Student Center	3	5.7	Meets target	0	97	0
23	SC126	Locker Room	Laney College	Student Center	3	3.6	Meets target	0	129	0
24	SC 1	Kitchen	Laney College	Student Center	3	3.0	Meets target	0	1361	0