




# Ventilation Assessment Summary

## Ventilation Assessment



#	HVAC		Site		Air Changes				PAC
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	CADR
1	<a href="#">315</a>	Office	Laney College	Tower	3	0.8	Does not meet target	55	1 X 66
2	<a href="#">313</a>	Office	Laney College	Tower	3	3.2	Meets target	0	
3	<a href="#">311</a>	Office	Laney College	Tower	3	3.5	Meets target	0	
4	<a href="#">309</a>	Office	Laney College	Tower	3	3.5	Meets target	0	
5	<a href="#">307</a>	Office	Laney College	Tower	3	4.6	Meets target	0	
6	<a href="#">305</a>	Office	Laney College	Tower	3	3.8	Meets target	0	
7	<a href="#">303</a>	Office	Laney College	Tower	3	2.7	Does not meet target	5	1 X 42
8	<a href="#">301</a>	Office	Laney College	Tower	3	9.0	Meets target	0	
9	<a href="#">302</a>	Office	Laney College	Tower	3	1.5	Does not meet target	25	1 X 42
10	<a href="#">304</a>	Office	Laney College	Tower	3	1.9	Does not meet target	19	1 X 42
12	<a href="#">308</a>	Office	Laney College	Tower	3	1.8	Does not meet target	20	1 X 42
13	<a href="#">310</a>	Office	Laney College	Tower	3	6.7	Meets target	0	
14	<a href="#">314</a>	Office	Laney College	Tower	3	7.4	Meets target	0	
15	<a href="#">312</a>	Office	Laney College	Tower	3	6.8	Meets target	0	
16	<a href="#">316</a>	Office	Laney College	Tower	3	11.2	Meets target	0	
17	<a href="#">351</a>	Office	Laney College	Tower	3	4.4	Meets target	0	
18	<a href="#">352</a>	Office	Laney College	Tower	3	3.6	Meets target	0	
19	<a href="#">350</a>	Office	Laney College	Tower	3	4.9	Meets target	0	
20	<a href="#">207</a>	Office	Laney College	Tower	3	3.9	Meets target	0	
21	<a href="#">209</a>	Office	Laney College	Tower	3	3.7	Meets target	0	
22	<a href="#">213</a>	Office	Laney College	Tower	3	4.2	Meets target	0	

#	HVAC		Site		Air Changes				PAC	
	Room	Type	Campus	Building	Target	Actual	Result	Min. CADR	CADR	
23	<a href="#">253</a>	Office	Laney College	Tower	3	4.4	Meets target	0	150	
24	<a href="#">211</a>	Office	Laney College	Tower	3	3.4	Meets target	0		
25	<a href="#">201 - 203</a>	Office	Laney College	Tower	3	2.2	Does not meet target	133		
26	<a href="#">210</a>	Office	Laney College	Tower	3	3.6	Meets target	0		
27	<a href="#">212</a>	Office	Laney College	Tower	3	4.0	Meets target	0		
28	<a href="#">214</a>	Office	Laney College	Tower	3	4.5	Meets target	0		
29	<a href="#">216</a>	Office	Laney College	Tower	3	4.4	Meets target	0		
31	<a href="#">256</a>	Office	Laney College	Tower	3	6.9	Meets target	0		
32	<a href="#">215</a>	Office	Laney College	Tower	3	9.2	Meets target	0		
33	<a href="#">Art Gallery</a>	Art Classroom	Laney College	Tower	3	3.2	Meets target	0		
35	<a href="#">3rd Floor Hallway</a>	Lobby	Laney College	Tower	3	0.6	Does not meet target	541		3 X 191
36	<a href="#">254/255</a>	Office	Laney College	Tower	3	6.8	Meets target	0		