

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0533:0106

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Viking Corp 210 N. Industrial Park Dr, Hastings, MI 49058
Contact: Debra Baker (269) 945-8233 Fax (269) 818-1680
Email: dbaker@vikingcorp.com

DESIGN: Model VFR-400 fire alarm control units. Automatic, manual, noncoded, local, remote station, central station, releasing device, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations.
Minimum system components:

VFR-400 Control Unit

Suitable for use with the following modules: RA-4410RC, CA2Z, CAM, ARM-1, ARM-2 and SG-32.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

These control units do not generate a Temporal Pattern Signal. If the distinctive three-pulse Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal.

This control unit meets the requirements of UL Standard 864, 9th edition.

XLF: 7165-0328:0170



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division