

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1689:100 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: FireFlex Systems Inc., 1935 Lionel-Bertrand Blvd., Boisbriand, Quebec, J7H1N8 Canada
Contact: Suzon Gauthier (450) 437-3473 FAX (450) 437-1930

DESIGN: ModelARC-1 Analog Release Controller fire alarm control unit. Local service, manual, automatic and automatic release of extinguishing systems. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120/240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name and manufacturing location, serial number and date code (on separate adhesive label), maximum electrical input and output ratings and FM Approval Mark.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

These control units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

05-29-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 1, 2007**

*Listing Expires **June 30, 2008***

Authorized By: **MIKE TANAKA**, Senior Deputy State Fire Marshal
Program Manager